



Ref. Certif. No.

HU-004324

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

MCB(Circuit-breakers for overcurrent protection)

Name and address of the applicant

Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

Name and address of the manufacturer

Zhejiang Tengen Electric Co., Ltd.  
Sulv Industrial Area, Liushi Town, Yueqing City,  
325604 Zhejiang  
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang Tengen Electric Co., Ltd. (Yueqing Economic  
Development Zone Branch) No.288 Central Avenue Development  
Zone, Yueqing City,  
325604 Zhejiang  
P.R. China

Ratings and principal characteristics

Ue: 220/380, 230/400, 240/415 V~(1Pole);  
380/400/415 V~ (2-,3-,4-Poles, 3-Poles+N);  
220/230/240 V~ (1Pole+N ); 50/60 Hz  
In: 1/2/3/4/5/6/10/16/20/25/32/40/50/63 A;  
B-, C- and D-Type Uimp:4kV;Icn=Ics:4.5kA

Trademark / Brand (if any)

TENGEN

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

TGB1N-63AP

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1  
See Test Report for National Differences

As shown in the Test Report Ref. No. which forms part of this Certificate

CN23KT0D 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2023-03-21

Signature:

Wencai Zhang

10/061SMD 2022-07 rke-fix